



2120 Forum Blvd., Ste. 101
Columbia, Missouri 65203
573.449.2683
Fax: 573.442.6213
www.PWArchitects.com

ADDENDUM #4

DATE: **January 12, 2021**

TO BIDDING DOCUMENTS ENTITLED:

**Columbia Public Schools
West Blvd. Elementary Kitchen Renovation**

PWA PROJECT NUMBER: 201621.50

BID DATE: **2:00 p.m. Thursday, January 14, 2021**

PREPARED FOR: **Columbia Public Schools**

CONSULTANT: **PWArchitects, Inc.
Attn: Chris Davis, AIA
Email: cdavis@PWArchitects.com**

Drawings and Specifications for the above noted project and the work covered thereby are herein modified as follows, and except as set forth herein, otherwise remain unchanged and in full force and effect:

General:

1. **Plan holders List:** A plan holders list is available online at www.adsmo.net or by calling ADS at (573) 446-7768.
2. **Kitchen Hood Clarification:** The HVAC contractor shall furnish and install the kitchen hood exhaust fan per the schedule on sheet FS3.0.

Attachments:

1. **None.**

END OF ADDENDUM